

# Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

## Arsenic Results Q2 CY15 - Point of Use (POU) Filters

**Instructions:**

1. Every month, take arsenic tests for POU filters on a rotating basis (check the Arsenic Sampling Schedule sheet for which POU filters) and record the results from the lab here.
2. At the end of every month, photocopy this updated log and send to RCAC Attn: Lee Schegg, 3120 Freeboard Dr. Suite 201, West Sacramento CA 95691. [lschegg@rcac.org](mailto:lschegg@rcac.org)

NOTE: In an event the arsenic result is over 10 ppb take the POU Out of Service and contact Tricia Wathen at (559) 447-3300 or Shen Huang at (559) 447-3484 to report immediately and get assistance.

		AUSD-SV2-POU		AUSD-SV3-POU		AUSD-SV4-POU		AUSD-SV6-POU		AUSD-SV7-POU		AUSD-HD12-POU	
		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Apr 2015	Record date												
	4/16/2015	32											
May 2015	5/5/2015		ND										
Jun 2015	6/11/2015			16	ND	17	ND	17	ND				
	6/12/2015									22	ND	26	ND

# Arvin Arsenic Interim Solutions DRAFT Arsenic Sampling Schedule

Site Sample ID	Arsenic Sample Schedule																								Samples per site	Outside Installs				
	2015						2016												2017											
	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr							
AUSD-ARFC-POU								x			x								x									3		
AUSD-ASW- POU								x		x	x								x	x									5	
AUSD-BME1-POU							x										x											2	x	
AUSD-BME2-POU							x										x											2	x	
AUSD-BME3-POU							x										x											2	x	
AUSD-BME4-POU							x										x											2	x	
AUSD-BME5-POU							x										x											2	x	
AUSD-BME6-POU							x										x											2	x	
AUSD-BME7-POU								x										x										2		
AUSD-BME8-POU								x										x										2		
AUSD-BME9a-POU								x										x										2	x	
AUSD-BME9b-POU								x										x										2	x	
AUSD-BME10-POU								x										x										2		
AUSD-BME11-POU								x		x		x		x		x		x			x			x		x		8		
AUSD-BME12-POU								x										x										2		
AUSD-ECR1-POU									x					x														2		
AUSD-ECR2- POU									x					x														2		
AUSD-ECR3- POU									x					x														2	x	
AUSD-ECR4- POU									x					x														2		
AUSD-ECR5- POU									x					x														2		
AUSD-ECR6- POU									x					x														2		
AUSD-ECR7- POU									x					x														2		
AUSD-ECR8- POU									x		x		x		x		x		x						x			7		
AUSD-HD1- POU		x		x								x									x							4	x	
AUSD-HD2- POU		x		x								x									x							4	x	
AUSD-HD3- POU		x										x									x							3	x	
AUSD-HD4- POU		x										x									x							3	x	
AUSD-HD5- POU		x										x									x							3	x	
AUSD-HD6- POU		x										x									x							3		
AUSD-HD7- POU		x										x													x			3	x	
AUSD-HD8- POU		x										x													x			3	x	
AUSD-HD9- POU		x										x													x			3	x	
AUSD-HD10- POU		x										x													x			3		

# Arvin Arsenic Interim Solutions DRAFT Arsenic Sampling Schedule

Site Sample ID	Arsenic Sample Schedule																								Samples per site	Outside Installs
	2015						2016												2017							
	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr			
AUSD-HD11- POU		x											x								x			3		
AUSD-HD12- POU			x	x		x		x		x		x		x		x		x		x		x		11		
AUSD-SV2- POU	x		x		x									x								x		5	x	
AUSD-SV3- POU	x		x		x									x								x		5	x	
AUSD-SV4- POU	x		x		x									x								x		5	x	
AUSD-SV5- POU			x		x									x								x		4	x	
AUSD-SV6- POU	x		x		x									x								x		5	x	
AUSD-SV7- POU	x		x		x		x		x		x		x		x		x		x		x			11		
AUSD-SV8- POU	x		x		x									x								x		5		
BMRD-AP-POU			x										x											2	x	
COA-FIELD-POU						x				x								x						3		
COA-VH-POU						x				x								x						3		
CSV-ACHC-POU				x						x								x						3		
CSV-ADO- POU				x						x								x						3		
KCGS-AL-POU						x				x								x						3		
STCC1-POU						x				x								x						3	x	
STCC2-POU						x				x								x						3	x	
No. Samples/Month	6	11	9	5	7	6	7	10	9	7	7	8	7	10	8	8	8	7	7	8	7	8				
% Sampled/Mo.	12%	22%	18%	10%	14%	12%	14%	20%	18%	14%	14%	16%	14%	20%	16%	16%	16%	14%	14%	16%	14%	16%			25	