

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

Arsenic Results Q3 CY15 - Point of Use (POU) Filters

Instructions:
 1. Every month, take arsenic tests for POU filters on a rotating basis (check the Arsenic Sampling Schedule sheet for which POU filters) and record the results from the lab here.
 2..At the end of every month, photocopy this updated log and send to RCAC Attn: Lee Schegg, 3120 Freeboard Dr. Suite 201, West Sacramento CA 95691. Ischegg@rcac.org

NOTE: In an event the arsenic result is over 10 ppb take the POU Out of Service and contact Tricia Wathen at (559) 447-3300 or Shen Huang at (559) 447-3484 to report immediately and get assistance.

	AUSD-SV7-POU		AUSD-BME11-POU		AUSD-ECR8-POU		AUSD-SV2-POU		AUSD-SV3-POU		AUSD-SV4-POU		
	PS Code	1510001-780	1510001-781	1510001-724	1510001-727	1510001-740	1510001-745	1510001-770	1510001-771	1510001-772	1510001-773	1510001-774	1510001-775
	Record date	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Jul 2015	7/10/2015								ND		ND		ND
	7/28/2015												
	7/29/2015		ND	14	ND	12	ND						
	7/30/2015												

Sample or result labels are reversed by comparison to other pre-filter data from same school.

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet
Arsenic Results Q3 CY15 - Point of Use (POU) Filters

	<i>PS Code</i>	AUSD-SV6-POU		AUSD-HD1-POU		AUSD-HD2-POU		AUSD-HD3-POU		AUSD-HD4-POU		AUSD-HD5-POU	
		1510001-778	1510001-779	1510001-746	1510001-747	1510001-748	1510001-749	1510001-750	1510001-751	1510001-752	1510001-753	1510001-754	1510001-755
		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Jul 2015	<i>Record date</i>												
	7/10/2015		ND										
	7/28/2015			30	ND	32	ND	28	ND	32	ND	31	ND
	7/29/2015												
	7/30/2015												

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

Arsenic Results Q3 CY15 - Point of Use (POU) Filters

		AUSD-HD8-POU		AUSD-HD9-POU		AUSD-HD10-POU		AUSD-HD11-POU		AUSD-HD13-POU		AUSD-ASW-POU	
<i>PS Code</i>		1510001-760	1510001-761	1510001-762	1510001-763	1510001-764	1510001-765	1510001-764	1510001-767	1510001-806	1510001-807	1510001-802	1510001-803
<i>Record date</i>		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Jul 2015	7/10/2015												
	7/28/2015	31	ND	27	ND								
	7/29/2015					30	HD	ND	ND			32	ND
	7/30/2015									29	ND		

BC Lab retested Pre-filter value and confirmed ND results

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

Arsenic Results Q3 CY15 - Point of Use (POU) Filters

		AUSD-ECR2-POU		AUSD-ECR4-POU		AUSD-ECR5-POU	
<i>PS Code</i>		1510001-732	1510001-733	1510001-736	1510001-737	1510001-738	1510001-739
<i>Record date</i>		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Jul 2015	7/10/2015						
	7/28/2015						
	7/29/2015						
	7/30/2015	ND	11	11	ND	10	ND

Sample or result labels are reversed by comparison to other pre-filter data from same school.

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

Arsenic Results Q3 CY15 - Point of Use (POU) Filters

		AUSD-SV7-POU		AUSD-HD12-POU		AUSD-BME11-POU		AUSD-ECR8-POU		AUSD-SV5-POU		AUSD-SV9-POU	
<i>PS Code</i>		1510001-780	1510001-781	1510001-764	1510001-769	1510001-724	1510001-727	1510001-740	1510001-745	1510001-776	1510001-777	1510001-780	1510001-805
<i>Record date</i>		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
Aug 2015	8/6/2015		ND										
	8/6/2015	21	ND							20	ND		
	8/7/2015				ND								
	8/7/2015			27	ND								
	8/13/2015						ND						
	8/13/2015					13	ND						
	8/26/2015											28	ND
	8/27/2015						ND		ND				
	8/28/2015					27	ND	29	ND				
	8/31/2015		ND										
		AUSD-SV7-POU		AUSD-BME11-POU		AUSD-HD2-POU							
<i>PS Code</i>		1510001-780	1510001-781	1510001-724	1510001-727	1510001-748	1510001-749						
<i>Record date</i>		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)						
Sep 2015	9/1/2015	21	ND										
	9/14/2015				ND								
	9/15/2015			19	ND								
	9/22/2015						ND						
	9/25/2015		ND										
	9/29/2015		ND										

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet
Arsenic Results Q3 CY15 - Point of Use (POU) Filters

	<i>PS Code</i>	AUSD-ECR9-POU		AUSD-BME13-POU	
		1510001-808	1510001-809	1510001-810	1510001-811
		Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)
<i>Record date</i>					
Aug 2015	8/6/2015				
	8/6/2015				
	8/7/2015				
	8/7/2015				
	8/13/2015				
	8/13/2015				
	8/26/2015	32	ND	31	ND
	8/27/2015				
	8/28/2015				
	8/31/2015				

	<i>PS Code</i>
	<i>Record date</i>
Sep 2015	9/1/2015
	9/14/2015
	9/15/2015
	9/22/2015
	9/25/2015
	9/29/2015

0