

Arvin Interim Solutions Arsenic Point of Use (POU) Filter Water Quality Results Tracking Sheet

Arsenic Results Master - Point of Use (POU) Filters

Instructions:

1. Every month, take arsenic tests for POU filters on a rotating basis (check the Arsenic Sampling Schedule sheet for which POU filters) and record the results from the lab here.
2. At the end of every month, photocopy this updated log and send to RCAC Attn: Lee Schegg, 3120 Freeboard Dr. Suite 201, West Sacramento CA 95691. lschegg@rcac.org

NOTE: In an event the arsenic result is over 10 ppb take the POU Out of Service and contact Tricia Wathen at (559) 447-3300 or Shen Huang at (559) 447-3484 to report immediately and get assistance.

	PS Code	AUSD-ECR2-POU		AUSD-HD11-POU		AUSD-SV2-POU		AUSD-SV3-POU		COA-FIELD		KCGS-AL		AH23-POU
		1510001-732	1510001-733	1510001-764	1510001-767	1510001-770	1510001-771	1510001-772	1510001-773	1510001-786	1510001-787	1510001-794	1510001-795	1510001-849
	Record date	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Pre Filter (µg/L)	Post Filter (µg/L)	Post Filter (µg/L)
Nov 2016	11/15/2016		ND		ND		ND		ND		ND		5.8	
	11/18/2016													ND
	11/21/2016													ND
	11/30/2016													